


PRODUCT CERTIFICATE OF REGISTRATION



Global Certification Pty Ltd

Number 40/24

Product Performance Testing

AS 1546.3:2017

Advanced Secondary 5000 L/day or 33.3EP Level with a reduction of 37.21% for Nitrogen and 15.27% for Phosphorus

Issued to

Taylex Australia Pty Ltd

56 Prairie Road Ormeau Qld 4208

Certification Date: - 16 December 2020 Expiry Date: - 16 December 2025

Product Certified:

Model	Disinfection	Average Results over the Test Period	Servicing Frequency	Discharge	Manufactured and assembled
Taylex Concrete ABS 5000	Yes	TSS 6.12mg/l BOD ₅ 1.07mg/l E coli 0.41 CFU/100ml Nitrogen 45.68 mg/l Phosphorus 9.21mg/l	3 Monthly Service 3.2 yearly sedimentation pump out or as required	Pumped via disinfection/pump chamber with chlorine dispenser	Manufactured and Assembled at: 56 Prairie Road Ormeau Qld 4208

The system took 4 weeks to meet the advanced secondary standard.
Note: The Ecoli result was compliant for the entire period from installation.
The vertical axis tanks are certified to AS/NZS 1546.1:2008

NACE CODES: 3700

This Certificate of Conformance to the Product Certificate Scheme for "Domestic Wastewater Treatment Units (Septic Tanks) and Rainwater Tanks" remains the property of Global Certification Pty. Ltd. and is granted subject to the terms and conditions of the Contract Application, in respect of the Product certified on this page and the attached schedule to the Certification of Conformance, bearing the same number as this certificate.

Date of Issue: 9 February 2021

Bruce Smith Director



www.jas-anz.com.au/register

Signed for and on behalf of Global Certification Pty Ltd
PO Box 953 Belconnen ACT 2616