

# PRODUCT CERTIFICATION



GLOBAL CERTIFICATION PTY LTD

*Certificate of Conformance*  
*Product Performance Testing*  
*AS/NZS 1546.3:2008*

*Number:* 040/8

*This Certificate of Conformance to the Product Certificate Scheme remains the property of Global Certification Pty. Ltd. and is granted subject to the terms and conditions of the Contract Application, in respect of the Product certified on this page and the attached schedule to the Certification of Conformance, bearing the same number as this certificate.*

Company: **TAYLEX AUSTRALIA PTY LTD**

Head Office Address: **56 PRAIRIE ROAD, ORMEAU, QLD 4208**

Recertification Date: **10 April 2016**

Expiry Date: **11 July 2025**

## Product Certified:

Tank Type	Description	Total Size	Working Capacity	Additional Product Information	Manufacture & Assembly Sites
Concrete ABS	Product manufactured using Collection Wells A,B, C,D,E,F,H,I,J total tank capacity 9,320 Ltrs, or using G & K Collection Wells total tank capacity 11,062 Ltrs.  Secondary with Nutrient reduction at 53.71% for nitrogen and 84.67% phosphorus removal at the 8EP and 10EP level using Chlorine as the disinfectant method.	9,320 Ltr or 11,062 Ltr	10EP 5,880Ltr 8EP 5009 Ltr	Over the test period the average results were: BOD5 1.0 g/m3 TSS 6.44 g/m3 Total Nitrogen 24.9mg/L Total phosphorus 2.5mg/L E.Coli and faecal coliform ND in any sample at the dilutions tested Turbidity 6.25 NTU Dissolved Oxygen 5.6 mg/L Average Aeration Chamber Temperature 21.05C	Manufactured and assembled at:  56 Prairie Road Ormeau, QLD 4208

5 November 2010

Certification Date

P0 Box 953, BELCONNEN ACT 2616

Director

Signed for and on behalf of Global Certification Pty Ltd

DATE OF ISSUE: 8 February 2021



JAS-ANZ

