



Contact: Keith Butterwick
Telephone: 8226 7100
Email: Keith.Butterwick@sa.gov.au

Date: 16 November 2020

Att: Steve Tedmanson
Taylex Industries Pty Ltd
56 PRAIRIE ROAD
ORMEAU QLD 3660

**Health Protection &
Licensing Services**

Citi Centre Building
11 Hindmarsh Square
Adelaide SA 5000

PO Box 6
Rundle Mall SA 5000
DX 243

Tel 08 8226 7100

Fax 08 8226 7102

ABN 97 643 356 590

www.health.sa.gov.au

Dear Steve,

RE: PRODUCT APPROVAL FOR THE TAYLEX INDUSTRIES PTY LTD, TAYLEX 22500 Lt T44 SEPTIC TANK, SEPTIC AND HOLDING TANKS

We refer to your application seeking product approval for the following Taylex Industries on-site wastewater system unit:

- 22500 L Concrete Septic Tank

The South Australian Public Health (Wastewater) Regulations 2013 allow for product approvals to be issued for a period of up to 5 years, after which an application for renewal of the product approval can be made.

The Global Certification Certificate of Conformance Number 40/20 provided in support of your application for product approval will expire on 11 July 2023. In order to enable a simpler 5 yearly renewal process, it has been determined that the product approvals in this instance will also expire on 11 July 2023.

Taylex Industries may apply for renewal of the product approvals prior to the expiry date. If a renewed Global Certification Certificate Licence is supplied to support the application, the Department for Health and Wellbeing will waive the application fee for renewal of the product approvals. The full application fee will be charged for consequent applications.

Karen Bennink
Manager, Wastewater Management
Delegate of the Minister for Health and Wellbeing



Contact: Keith Butterwick
Telephone: 8226 7100
Email: healthwastewatermanagement@sa.gov.au

Health Protection & Licensing Services

Citi Centre Building
11 Hindmarsh Square
Adelaide SA 5000

PO Box 6
Rundle Mall SA 5000
DX 243

Tel 08 8226 7100
Fax 08 8226 7102

ABN 97 643 356 590

www.health.sa.gov.au

Product Approval Number: **WWP-20075**

18 November 2020

Att: Steve Tedmanson
Taylex Industries Pty Ltd
56 PRAIRIE ROAD
ORMEAU QLD 3660

Dear Mr Tedmanson,

RE: PRODUCT APPROVAL FOR THE TAYLEX INDUSTRIES PTY LTD, TAYLEX 22500L T44 SEPTIC TANK, SEPTIC AND HOLDING TANKS

We refer to your application seeking product approval for the Taylex Industries Pty Ltd, Taylex 22500 Lt T44 Septic Tank, on-site domestic wastewater treatment unit.

Approval of the product is granted on the basis that the product has been certified by Global Certification Pty Ltd to conform with:

- AS/NZS 1546.1:2008 - On-site domestic wastewater treatment units – Septic tanks, as demonstrated by Global Certification Certificate of Conformance Number 40/20

Pursuant to the South Australian Public Health (Wastewater) Regulations 2013, product approval is subject to the following conditions:

1. The approved product incorporate:
 - 1.1. 1 x 22500 L Concrete Septic Tank
2. The products shall be manufactured and constructed in accordance with:
 - 2.1. The plans, drawings and specifications, as referenced in this approval.
 - 2.2. AS/NZS 1546.1:2008 – On-site domestic wastewater treatment units – Septic tanks.
 - 2.3. All other relevant standards and codes.
 - 2.4. Conditions of this approval.
3. The seller of the approved product shall provide the purchaser with an electronic or hard copy of:

OFFICIAL

- 3.1. The TAYLEX INDUSTRIES PTY LTD 22500 LITRE T44 – SEPTIC TANK – INSTALLATION MANUAL
- 3.2. The TAYLEX INDUSTRIES PTY LTD 22500 LITRE T44 – SEPTIC TANK – SERVICEMAN PROCEDURE
- 3.3. Any other instructions relating to the installation, operation or maintenance of the product.
4. Modification of the design, materials or manufacturing process of the approved products or any of their associated components requires a variation to this approval by the Department for Health and Wellbeing.
5. The product approval will expire on 11 July 2023, at which time the products will no longer be approved and will be removed from the SA Health approved product database.
6. This product approval does not constitute approval for the installation of the product.

Approved by:

Date: **18 November 2020**



Karen Bennink

Manager, Wastewater Management

Delegate of the Minister for Health and Wellbeing

References: The following documents, submitted by Taylex Industries Pty Ltd

- 22500 Litre T44 – Septic Tank APPLICATION FOR PRODUCT APPROVAL SOUTH AUSTRALIA.pdf
 - Concept Report
 - Description of the Proposed Treatment and/or Technology
 - Engineering Calculations
 - Technical Specifications for the Components within the System
 - Schematic Plan of the Overall System
 - Installation & Lifting Instructions
 - Servicing Manual/Details
 - Certification ISO9001:2015
 - Certification Product Standard 1546.1.2008

Notes:

Pursuant to the SA Public Health (Wastewater) Regulations 2013

1. *The Department for Health and Wellbeing (DHW) may, by written notice, revoke the approval if satisfied that:*
 - 1.1. *The approval was obtained improperly.*

WWP-20075

Product Approval for the Taylex 22500 Lt T44 Septic Tank

Page 2 of 3

OFFICIAL

OFFICIAL

- 1.2. *A condition of the approval has been contravened.*
2. *The DHW may conduct an inspection of an approved product to establish compliance with the submitted plans and the conditions of this approval.*
3. *The DHW may vary or revoke any or all of the approval conditions, or impose a further condition where:*
 - 3.1. *Variation, revocation or imposition is necessary in order to prevent or mitigate significant harm to public or environmental health or the risk of such harm.*

Reference to a new version of a manua